







BMS CABLE

Document ID: TE/QMS/F/02 DESIGN CODE: ICBS04CYUAYL004C001S

Name of Manufacturer Polycab India Ltd Type of Cable Screened BMS Cable No of Elements X Size in mm² (No X Sq.mm) 4C X 1			
No of Floments V Size in mm ² /No V Samm)			
No of Elements A Size in mini- (No A Sq.mm) 4C A 1			
Voltage Grade (Volts) 300/500			
Applicable standard (S) Generally as per BSEN 50288-7			
Conductor			
a) Material Plain annealed high conductivity Flexible copper copper conductivity Flexible copper copper copper copper copper copper			
b) Maximum d.c. resistance of conductor at 20° C $$(\Omega/\text{km})$$			
c) Shape of conductor Bunched Circular			
Insulation			
a) Material Extruded PVC Type 'A'			
b) Minimum Thickness (mm) 0.44			
c) Core Identification Red, Yellow, Blue & Yellow-Green			
Collective Screen			
a) Material Aluminium mylar tape			
b) Nominal Thickness (mm) 0.018			
c) Material of Drain Wire Flexible ATC			
d) Size of Drain Wire (Sq.mm) 0.5 mm² (16/0.2 mm)			
Outer sheath			
a) Material Extruded FR-LSH PVC Type ST1			
b) Nominal thickness (mm) 0.92			
c) Colour Of Outersheath Blue			
Approximate Overall diameter of cable (mm) 7.9 ± 1.0			
Maximum conductor temperature under normal operating conditions (°C)			
Maximum conductor temperature at the termination of short circuit (°C)			
Minimum bending radius (mm) 12 times Overall diameter			





Electrical Parameters			
a)	Max. a.c. resistance of conductor at operating temperature (Ω/km)	23.3	
b)	Mutual capacitance (nf/km)	<250	
c)	Insulation resistance (M Ω /km)	10	
d)	Inductance to resistance ratio (L/R) ($\mu H/\Omega$)	<25	
e)	Dielectric strength for 1 minute (H.V Test) (kV)	2.0	
	tensile strength for Cables pulled with ing (Newtons)	$9 \times D^2$, D is the cable OD in mm	
FR-LSH PROPERTIES			
a)	Oxygen Index	Min. 29% as per ASTM D- 2863	
b)	Temperature Index	Min. 250 Deg.C as per ASTM D- 2863	
c)	Smoke Density Rating	Max. 60% as per ASTM D- 2843	
d)	Acid Gas Generation	Max. 20% as per IEC- 754- 1	
e)	Flammability Test	As per IEC:60332-1	
Printi	ng	YEAR POLYCAB 300/500 VOLTS GRADE FR-LSH No of Core x Sqmm SCREENED WITH SEQUENTIAL MARKING AT EVERY ONE METER	

Rev. No.: 00 Issued date:20/04/2022