



Customer :

Technical Particulars of PVC Instrumentation Cables

| S.No | Particulars | UNIT | 1P X 1 | 2P X 1 | 3P X 1 | 4P X 1 | 5P X 1 | 6P X 1 | 7P X 1 | 8P X 1 |
|------|----------------------|------|--------|--------|--------|--|--------|--------|--------|--------|
| a) | Oxygen Index | | | | | Min. 29% as per ASTM D- 2863 | | | | |
| b) | Temperature Index | | | | | Min. 250 Deg.C as per ASTM D- 2863 | | | | |
| c) | Smoke Density Rating | | | | | Max. 60% as per ASTM D- 2843 | | | | |
| d) | Acid Gas Generation | | | | | Max. 20% as per IEC- 754- 1 | | | | |
| e) | Flammability Test | | | | | As per IEC:332-I | | | | |
| 17 | Embossing | | | | | POLYCAB 500 VOLTS GRADE FRLS | | | | |
| 18 | Printing | | | | | YEAR POLYCAB 500 VOLTS GRADE FRLS No of Pair x Sqmm SCREENED WITH SEQUENTIAL MARKING AT EVERY ONE METER.. | | | | |

FOR POLYCAB WIRES PVT LTD