

UNIVERSAL CABLES LTD P.O. Birla Vikas Satna - 485005



TECHNICAL PARTICULARS		
Sr. No.	Description	4C x 4 mm ²
1	Trade Name	"UNISTAR"
2	Reference Standard	IS: 9968/1/88
3	Voltage Grade	1100 Volts
4	Conductor	
	a) Material to IS : 8130/84	Annealed Tinned Copper
	b) Nominal Cross sectional Area (mm²)	4
	c) Flexibility Class as per IS : 8130/84	Class-5
	d) Max. DC. Resistance at 20°C (Ohm/Km)	5.09
5	Insulation	
	a) Material to IS : 6380/84	EPR Type IE-2
	b) Nominal Thickness (mm.)	1.00
6	Core Identification	By number printing or by coloured insulation Red, Yellow, Blue & Green
7	No. of Cores	4
8	Laying Up	Cores laid up together suitably
9	Outer Sheath	
	a) Material to IS: 6380/84	PCP Type SE-3 (Black Colour)
	b) Nominal Thickness (mm.)	1.30
10	Max. Overall Diameter of Cable (mm.)	16.5
11	Max. Conductor Temperature for continuous operation	90°C
12	Recommended Minimum bending radius	6 x Overall diameter of the cable
13	Continuous current rating in air at ambient temperature 40°C (Amps)	38
14	Derating factor for variation in ambient air temperature	
	a) Temperature	30 35 40 45 50 55
	b) Rating factor	1.12 1.06 1.00 0.94 0.86 0.80
15	Identification and Marking	Manufacturer's Name and/or Trade Name and HR-90 shall be identified throughout the cable length at interval not exceeding one meter either by printed tape in the cable or by printing on the outer sheath.